

## TYPICAL FOOTPATH SECTION

Not to Scale

## TYPICAL FOOTPATH REQUIREMENTS FOR WELL DRAINED SUBGRADES

TRAFFIC	MINIMUM THICKNESS (mm)	MAXIMUM CONTROL JOINT SPACING (m)	MINIMUM REINFORCEMENT
FOOT & BICYCLE	75	2.5 - 3.0	NONE
LIGHT VEHICLE	100	3.0	NONE
HEAVY VEHICLE	150	4.0	F72


### NOTES:

- Construction Joints are to be made through the footpath at the driveway edges and @ maximum 3m intervals along footpath.
- Construction Joints are also to be made between footpath and any additional concrete requested.
- Expansion Joints are to be made every 15 metres, filled with an approved gap filler.
- Footpath surface should have a slip resistant (soft broomed) finish.
- Footpaths are to be backfilled with Loam (grassed verges) or Quarry Sand from stonyfell Quarry (ungrassed verges).

ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN

## THE CORPORATION OF THE CITY OF MARION

### CONCRETE FOOTPATH DETAILS

	Drawn : A.M.D	Date : 31 June 2007	Approved : .....
	Last Revised : 1 FEB 2017		Ref. No. : SD-03