

AC10 WEARING COURSE (MEDIUM DUTY MIX)

50

↑

BASE COURSE:  
200mm PM1/20QG IN TWO LAYERS  
TO 98% OF MDD MODIFIED COMPACTION  
(AS 1289.5.2.1)

SUB-BASE:  
200mm PM2/20QG IN TWO LAYERS  
TO 98% OF MDD MODIFIED COMPACTION  
(AS 1289.5.2.1)

BACKFILL SAND TYPE C (WHERE REQUIRED)  
PLACED IN MAXIMUM 200mm (LOOSE) LAYERS  
TO 98% MODIFIED COMPACTION

HAUNCH, SIDE & OVERLAY SAND TYPE D  
PLACED IN MAXIMUM 200mm (LOOSE) LAYERS  
TO 95% MODIFIED COMPACTION

STORMWATER PIPE

D

200

BEDDING SAND TYPE D  
TO 95% MODIFIED COMPACTION

100

↑

$D/6$  OR 300mm - WHICHEVER THE GREATER

Not to Scale

ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SHOWN.

# THE CORPORATION OF THE CITY OF MARION

## STORMWATER TRENCH REINSTATEMENT IN ROADS



Drawn : A.M.D

Date : 17 Sept. 2007

Approved :

Last Revised : 16 November 2018

Ref. No. : SD-17